

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surface and flush mounted installation boxes
Name and address of the applicant	Tehnoplast d.o.o. Zdravka Jekića 119, 22305 Stari Banovci, Serbia
Name and address of the manufacturer	Tehnoplast d.o.o. Zdravka Jekića 119, 22305 Stari Banovci, Serbia
Name and address of the factory	Tehnoplast d.o.o. Zdravka Jekića 119, 22305 Stari Banovci, Serbia
<i>Note: When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	400 V a.c./ 1000 V d.c.; IP40, Class II; IK07
Trademark / Brand (if any)	TEHNOPLAST
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Surface mount: N4C, N8C, N12C, N18C, N24C, N36C, N48C, N1x24C, N2x24C, N2x18C, N3x18C, N4x18C Flush mount: U4C, U8C, U12C, U18C, U24C, U36C, U48C, U1x24C, U2x18C; U3x18C
Additional information (if necessary may also be reported on page 2)	See the Test Report for information about National Differences. <input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62208:2023
As shown in the Test Report Ref. No. which forms part of this Certificate	T211-0386/25 (2025-05-12)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasićeva ulica 10, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services (SIST EN ISO/IEC 17065).

Date: 2025-05-12

Signature: Matej Žontar

