



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **47572-001-10**

Valid from: 2025 12 31
until: 2026 09 06

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **TEHNOPLAST D.O.O.**
Zdravka Jekica 119
22305 Stari Banovci
Serbia

Product: **Empty enclosures for low voltage switchgear and controlgear assemblies**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 37706A**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at



Wien, 2026 02 02

Dipl.-Ing. T. Neumayer

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

TEHNOPLAST D.O.O.
Zdravka Jekica 119
22305 Stari Banovci
Serbia

Factory location(s):

TEHNOPLAST D.O.O.
Zdravka Jekica 119
22305 Stari Banovci
Serbia

Tested and certified according to:

ÖVE/ÖNORM EN 62208:2012-07-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Empty enclosures for low voltage switchgear and controlgear assemblies

Type designation:

Rating:

Trademark:

N4C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40 / IK 07
surface mounting

TEHNOPLAST

N8C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

N12C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

N18C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

N24C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

N36C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

N48C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

N1x24C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40 / IK 07
surface mounting

TEHNOPLAST

N2x18C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

N3x18C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
surface mounting

TEHNOPLAST

N4x18C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40 / IK 07
surface mounting

TEHNOPLAST

U4C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40 / IK 07
flush mounting

TEHNOPLAST

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

U8C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
flush mounting

TEHNOPLAST

U12C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
flush mounting

TEHNOPLAST

U18C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
flush mounting

TEHNOPLAST

U24C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
flush mounting

TEHNOPLAST

U36C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
flush mounting

TEHNOPLAST

U48C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40 / IK 07
flush mounting

TEHNOPLAST

U2x18C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
flush mounting

TEHNOPLAST

U3x18C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40
flush mounting

TEHNOPLAST

U1x24C

Rated supply voltage: AC 400 V
Class of protection: II
IP 40 / IK 07
flush mounting

TEHNOPLAST

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.