



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **47572-009-03**

Valid from: 2025 06 15
until: 2026 09 06

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **TEHNOPLAST D.O.O.**
Zdravka Jekica 119
22305 Stari Banovci
Serbia

Product: **Installation boxes (empty enclosures)**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 39370A**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at



Wien, 2025 04 09

Dipl.-Ing. T. Neumayer

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

TEHNOPLAST D.O.O.
Zdravka Jekica 119
22305 Stari Banovci
Serbia

Factory location(s):

TEHNOPLAST D.O.O.
Zdravka Jekica 119
22305 Stari Banovci
Serbia

Tested and certified according to:

ÖVE/ÖNORM EN 62208:2012-07-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Installation boxes (empty enclosures)

Type designation:

Rating:

Trademark:

U12E...

Rated insulation Voltage: AC 400 V
IP 30 or IP 40; IK08
flush mounted

TEHNOPLAST

U24E...

Rated insulation Voltage: AC 400 V
IP 30 or IP 40; IK08
flush mounted

TEHNOPLAST

U36E...

Rated insulation Voltage: AC 400 V
IP 30 or IP 40; IK08
flush mounted

TEHNOPLAST

U48E...

Rated insulation Voltage: AC 400 V
IP 30 or IP 40; IK08
flush mounted

TEHNOPLAST

U60E...

Rated insulation Voltage: AC 400 V
IP 30 or IP 40; IK08
flush mounted


TEHNOPLAST

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Type code:

U ** E * ** ***



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.